

J. Will Johnson Tanks Roof Repairs Project (EO-3630)

Board of Water Commissioners
September 29, 2022



Long Beach Water
Exceptional Water • Exceptional Service

Background



- J. Will Johnson Reservoir located near 2200 E. University Drive in the City of Compton
 - 12 potable water tanks on site
- Tanks 4, 5, 6, and 8:
 - Constructed in 1940s
 - 3.3 million-gallon capacity
 - Welded steel shell and wood roof

Scope of Work

- Install new roofing systems
 - Replace damaged tongue and groove decking
- Repair of tanks:
 - Repair/replace roof hatches
 - Repair/install guardrails
 - Install new fall restraint systems
 - Replace vent screening
 - Install new liquid level indicators
 - Install new cathodic protection systems



Existing Conditions



Recommendation

Adopt Specifications WD-58-22 for the J. Will Johnson Tanks Roof Repair Project (EO-3630) and authorize the General Manager to sign a construction contract with Advanced Industrial Services, Inc., in the amount of \$2,791,300.



Long Beach Water

Exceptional Water • Exceptional Service