

Project Description & Background

- Since March 2017, several leaks detected on copper service laterals on Golden Ave.
- Stray current investigation was performed to determine cause of leaks.
- Project work involves:
 - Replacement of approx. 1,300 linear feet of 6-inch ductile iron main and 48 copper water services with new non-metallic piping
 - Surface restoration
 - Traffic control




Failed Copper Service Lateral
Pipe Samples



Project Location

Golden Ave between 32nd St & Spring St







Timeline

Construction Duration:

120 Calendar Days

Anticipated Construction Start:

• Summer 2023

Involved Parties:

- Construction Management (CM): Dudek
- Inspection: LBUD Inspection Staff



Recommendation

Adopt Specifications WD-54-22 for the Golden Avenue Water Main Replacement Project (MC-5223) and authorize the General Manager to sign a construction contract with Gutierrez Pipeline, Inc., in the amount of \$758,971.

